



**BRANZ Appraised**

Appraisal No.436 [2005]

**BRANZ Appraisals**

Technical Assessments of products  
for building and construction

**BRANZ  
APPRAISAL  
CERTIFICATE  
No. 436 (2005)**

**BUTYNOL®  
ROOFING  
MEMBRANE**

**Ardex NZ Ltd**  
P O Box 19549  
Woolston  
Christchurch

Tel: 03 384 3029  
Fax: 03 384 9779  
www.butynol.co.nz



**BRANZ Limited**  
Private Bag 50 908  
Porirua City  
New Zealand  
Tel: +64 4 237 1170  
Fax: +64 4 237 1171  
www.branz.co.nz

**BRANZ Pty Ltd**  
P O Box 830  
Brookvale  
NSW 2100  
Australia  
Tel: +61 2 9938 6011  
Fax: +61 2 9938 6911  
www.branz.com.au



## Product

1.1 Butynol® Roofing Membrane is a synthetic rubber waterproofing membrane designed to be used on roofs and decks.

1.2 The product is supplied as single-ply, flexible synthetic rubber sheet in roll form. The product is installed as a single layer system.



Current View of Christchurch Town Hall.  
1 mm Butynol® Roof Membrane laid 1972.

## Scope

2.1 Butynol® Roofing Membrane has been appraised for use as waterproofing membrane for buildings within the following scope:

- scope limitations of NZBC Acceptable Solution E2/AS1, Paragraph 1.1; and,
- with timber supporting structures designed and constructed in accordance with the NZBC; and,
- with nominally flat or pitched roofs constructed to drain water to gutters and drain outlets complying with NZBC; and,
- with substrates of plywood sheet; and,
- with decks that have a maximum size of 40m<sup>2</sup>.

2.2 Butynol® Roofing Membrane has also been appraised for use as waterproofing membrane for external reinforced concrete and plywood roofs, pedestrian decks and balconies for buildings within the following scope:

- up to 3 storeys with a maximum height from ground to eaves of 10m and with a floor plan area limited only by seismic and structural control joints; and,
- with the reinforced concrete structure designed and constructed in accordance with the NZBC; and,
- with timber supporting structures designed and constructed in accordance with the NZBC; and,
- with nominally flat, curved or pitched roofs constructed to drain water to gutters and drain outlets complying with NZBC.

2.3 This Appraisal is limited to roofs, decks and balconies within the following scope:

- constructed to suitable falls (Refer Paragraph 13.1 – 13.9); and,
- with no steps within the deck level, no integral roof gardens and no down pipe discharging directly onto the deck.

2.4 The design and construction of the substrate and movement and control joints is specific to each building, and therefore the responsibility of the building designer and building contractor and is outside the scope of this Certificate.

2.5 The membrane must be installed by Ardex NZ Ltd approved applicators.

## Building Regulations

### New Zealand Building Code (NZBC)

**3.1 In the opinion of BRANZ, Butynol® Roof Membrane, if designed, used, installed and maintained in accordance with the statements and conditions of this Certificate, will meet or contribute to meeting the following provisions of the NZBC:**

**Clause B2 DURABILITY:** Performance B2.3.1 (b) 15 years. Butynol® Roof Membrane meets this requirement. See Paragraph 9.1.

**Clause E2 EXTERNAL MOISTURE:** Performance E2.3.1 and E2.3.2. Roofs, Decks and balconies incorporating Butynol® Roof Membrane meets these requirements. See Paragraphs 12.1 – 12.9.

**Clause F2 HAZARDOUS BUILDING MATERIALS:** Performance F2.3.1. Butynol® Roof Membrane meets this requirement and will not present a health hazard to people.

3.2 This Certificate appraises an Acceptable Solution in terms of New Zealand Building Code compliance and the product complies with NZBC Acceptable Solution E2/AS1 Paragraph 8.5. This product is also appraised as an Alternative Solution as outlined in Paragraph 2.2

## Technical Specification

4.1 Materials supplied by Ardex NZ Ltd are as follows:

### Butynol® Membranes

- All membranes are single-ply, flexible synthetic rubber membranes. They are supplied in rolls nominally 1.4 metres wide by 17.9 metres long. Each roll is packed in polythene wrapper trademarked 'Butynol®' with thickness identified. Gauges available are 1.0, 1.5 and 2.25mm in black and 1.5mm in six colours.

### Adhesive WA98

- A specially formulated solvent-based adhesive for all Butynol® applications. Supplied in 1, 4 and 20 litre containers.

### Seam Primer

- A water resistant primer adhesive, used with seam tape for general lap bonding.

### Seam Tape

- Uncured cold gum tape used for general lap bonding and laps likely to be subject to periodic ponding. Supplied in 50mm x 30.5 metre rolls.

### Flashing Tape

- A malleable tape for moulding gussets, pipe flashings and awkward situations. Supplied in widths of 50-100mm x 5 metres long.

### Butynol Sealant

- A specially designed and formulated sealant for sealing Butynol® flashings into chases. Supplied in 375mm tubes.

## Handling and Storage

5.1 Handling and storage of all materials whether on or off site is under the control of the Ardex NZ Ltd trained installers. Dry storage must be provided for all products and the rolls of membrane must be stored in an upright position.

## Technical Literature

6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for the Butynol® Roofing Membrane. The Technical Literature must be read in conjunction with this Certificate. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Certificate must be followed.

## Design Information

### General

7.1 Butynol® Roofing Membrane is for use on roofs, decks and balconies where an impervious waterproof membrane is required to prevent damage to building elements and adjoining areas.

7.2 The 1.0mm thickness product is designed for use on roofs and gutters, and will accommodate light traffic; the 1.5mm is for walk out decks and high maintenance areas; and the 2.25mm is a heavy duty product that is custom made on request.

7.3 The effective control of internal moisture must be considered at the design stage due to the impermeability of the membrane. Refer to BRANZ publication "Good Practice Guide to Membrane Roofing".

7.4 Timber framing systems must comply with NZS 3604, or where specific engineering design is used, the framing shall be of at least equivalent stiffness to the framing provisions of NZS 3604, or comply with the serviceability criteria of NZS 4203. In all cases framing must be provided so that the maximum span of the substrate as specified by the substrate manufacturer is met and that all sheet edges are fully supported.

### Building to NZBC Acceptable Solution E2/AS1

7.5 NZBC Acceptable Solution E2/AS1 limits the size of decks to 40 m<sup>2</sup> as covered by the scope of this Appraisal. Butynol® Roofing Membrane is suitable for use on decks larger than 40 m<sup>2</sup>. These decks are the subject of specific design and are outside the scope of this Appraisal.

## Substrates

### Plywood

8.1 Plywood must be treated to H3 (CCA treated). LOSP treated plywood must not be used. Plywood must comply with NZBC Acceptable Solution E2/AS1 Paragraph 8.5.3 and 8.5.5. Where specific design is used (i.e. outside the scope of E2/AS1), the plywood thickness and fixing size may increase and centres may decrease to meet specific wind loadings.

### Concrete

8.2 Concrete substrates must be to a specific engineering design meeting the requirements of the NZBC, such as concrete construction to NZS 3101.

## Durability

### Serviceable Life

9.1 Butynol® Roofing Membrane when subjected to normal conditions of environment and with proper maintenance can expect to have a serviceable life of at least 20 years.

## Maintenance

10.1 No maintenance of the membrane is normally required provided significant substrate movement does not occur.

10.2 In the event of damage to the membrane, the membrane must be repaired by removing the damaged portion and applying a patch as for new work.

10.3 Drainage outlets must be maintained to operate effectively.

## Outbreak of Fire

11.1 The membrane must be protected from heat sources such as flues and chimneys in accordance with the requirements of NZBC Acceptable Solution C/AS1 Part 9 for the protection of combustible materials.

## External Moisture

12.1 Roofs, decks and balconies must be designed and constructed to shed precipitated moisture. They must also take account of snowfalls in snow prone areas. A means of meeting code compliance with NZBC Clause E2.3.1 is given by the Technical Literature which matches details in NZBC Acceptable Solution E2/AS1.

12.2 When installed in accordance with this Certificate and the Technical Literature, Butynol® Roofing Membrane will prevent the penetration of water and will therefore meet code compliance with Clause E2.3.2. The membrane is impervious to water and will give a weathertight roof, roof deck or balcony.

12.3 The minimum fall to roofs is 1 in 40 and to decks, balconies and gutters are 1 in 60. All falls must slope to an outlet. Inadequate falls will allow moisture to collect and increase the risk of deterioration of the membrane.

12.4 Butynol® Roofing Membrane is impermeable; therefore a means of dissipating construction moisture must be provided in the building design and construction to meet code compliance with Clause E2.3.6.

12.5 Roof, deck and balcony falls must be built into the substrate and not created with mortar screeds applied over the membrane.

12.6 Allowance for deflection and settlement of the substrate must be made in the design of the deck or balcony to ensure falls are maintained and no ponding of water can occur.

12.7 Drainage flanges must be used for any outlet and must be fitted with a grate or cage to reduce potential sources of blockages. An overflow must be provided where the deck or balcony does not drain to an external gutter or spouting.

12.8 Penetrations and upstands of the membrane must be raised above the level of any possible flooding caused by blockage of deck and balcony drainage.

12.9 The design of details not covered by the Technical Literature is subject to specific weathertightness design and is outside the scope of this certificate.

## Water Supplies

13.1 Butynol® Roofing Membrane is suitable for roofs used for the collection of water supplies in compliance with the provisions of NZBC G12.3.1. Water collection systems are the subject of specific design and are outside the scope of this Certificate.

## Installation Information

### Installation Skill Level Requirement

14.1 Installation of the membrane must be completed by trained applicators, approved by Ardex NZ Ltd.

14.2 Installation of substrates must be completed by tradespersons with an understanding of roof, deck and balcony construction, in accordance with instructions given within the Ardex NZ Ltd Technical Literature and this Certificate.

## Preparation of Substrates

15.1 Substrates must be dry, clean and stable before installation commences. Surfaces must be smooth and free from nibs, sharp edges, dust, dirt or other materials such as oil, grease or concrete formwork release agents. All surface defects must be filled to achieve an even and uniform surface.

15.2 Concrete substrates can be checked for dryness by using a hygrometer, as set out in BRANZ Bulletin No. 424. The relative humidity of the concrete must be 75% or less before membrane application.

15.3 The moisture content of a timber substructure must be a maximum of 20% and plywood sheet must be dry at time of membrane application. This will generally require plywood sheets to be covered until just before the membrane is laid, to prevent rain wetting.

15.4 Substrates must be primed with a 50/50 solution of WA98 and adhesive solvent and left to dry before membrane is installed.

## Membrane Installation

16.1 The membrane must be installed in accordance with the Technical Literature.

16.2 Plywood joints must be taped with 25mm wide PVC pressure sensitive tape.

16.3 The membrane must be unrolled without tension onto the prepared substrate and allowed to 'relax' for at least 20 minutes prior to installation.

16.4 Adhesive must be applied to both the membrane and the substrate, one half at a time. When the adhesive is tack dry, the sheet is rolled onto the substrate. The process is then repeated for the other half of the sheet. Joints in substrates with a pitch of 5° or less, all coloured membranes irrespective of pitch, all guttering and areas subjected to periodic ponding require lap bonding using Ardex seam tape. Joints in substrates with a pitch above 5° can be sealed using WA98 adhesive. This applies to the black Butynol® only.

## Inspections

17.1 The Technical Literature must be referred to during the inspection of membrane installations by Building Consent Authorities and Territorial Authorities.

17.2 Critical areas of inspection for waterproofing systems are:

- Construction of substrates, including crack control and installation of bond breakers and movement control joints.
- Moisture content of the substrate prior to the application of the membrane.
- Acceptance of the substrate by the membrane installer prior to application of the membrane.
- Installation of the membrane to the manufacturer's instructions.

## Health and Safety

18.1 Safe use and handling procedures for the membrane system is provided in the Technical Literature.

The products must be used in conjunction with the relevant Materials Safety Data Sheet for each membrane.

## Basis of Appraisal

The following is a summary of the technical investigations carried out:

### Tests

19.1 Tests have been carried out on the membrane by Materials and Quality Consultancy Ltd. This testing covered specific gravity, shore hardness, tensile strength, modulus of elongation, elongation at break, tensile and elongation retention after heat aging, tear strength, ozone resistance and water absorption as detailed in NZBC Acceptable Solution E2/AS1 Paragraph 8.5.4(b). Results and test methods have been reviewed by BRANZ and found to be satisfactory.

19.2 Water vapour permeability tests have been undertaken by BRANZ in accordance with ASTM E96.

19.3 Tests have been carried out on the membrane to assess its suitability for use with potable water supplies. This testing showed the product was satisfactory.

19.4 The adhesives, primers and seam tapes used with Butynol® Roofing Membrane meet the intended performance requirements of NZBC Acceptable Solution E2/AS1 Paragraph 8.5.4(c). *Note: At the time of this Certificate's issue BRANZ EM5 as outlined on Paragraph 8.5.4(c)(i) was not published.*

### Other Investigations

20.1 An assessment was made of the durability of the Butynol® Roofing Membrane by BRANZ technical experts using NZBC B2/VM1 History of Use.

20.2 Site visits have been carried out by BRANZ to assess the practicability of installation, and to examine completed installations.

20.3 The Technical Literature has been examined by BRANZ and found to be satisfactory.

### Quality

21.1 The manufacture of the Butynol® Roofing membrane has been examined by BRANZ, and details regarding the quality and composition of the materials used were obtained by BRANZ and found to be satisfactory. The membrane manufacturer is the subject of AS/NZS ISO 9001 Certificate by Telarc Limited, Registration No. 621.

21.2 The quality of manufacture of the product is the responsibility of Ardex NZ Ltd.

21.4 The quality of supply of the product to the market is the responsibility of Ardex NZ Ltd.

21.5 Quality on site is the responsibility of the Ardex NZ Ltd approved applicators.

21.6 Designers are responsible for the substrate design, and building contractors are responsible for the quality of construction of substrate systems in accordance with the instructions of the substrate manufacturer, Ardex NZ Ltd and this Certificate.

### Sources of Information

- AS/NZS 2269:1994 Plywood – Structural
- ASTM E 96-02 Water vapour transmission of materials in sheet form, American Society of Testing Materials, Philadelphia, 1992.
- NZS 3101: 1995 The design of concrete structures.
- NZS 3604: 1999 Timber framed buildings.
- Compliance Document for New Zealand Building Code External Moisture Clause E2, Department of Building and Housing, Third Edition July 2005.
- New Zealand Building Code Handbook and Approved Documents, Building Industry Authority, 1992.
- The Building Regulations 1992, up to, and including October 2004 Amendment.
- Membrane Roofing Good Practice Guide, BRANZ, November 1999



**BRANZ**

**In the opinion of BRANZ, Butynol® Roofing Membrane is fit for purpose and will comply with the Building Code to the extent specified in this Certificate provided it is used, designed, installed and maintained as set out in this Certificate. The Appraisal Certificate is issued only to the Certificate Holder, Ardex NZ Ltd, and is valid until further notice, subject to the Conditions of Certification.**

### Conditions of Certification

1. This Certificate:
  - a) relates only to the product as described herein;
  - b) must be read, considered and used in full together with the technical literature;
  - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
  - d) is copyright of BRANZ.
2. The Certificate Holder:
  - a) continues to have the product reviewed by BRANZ;
  - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
  - c) abides by the BRANZ Appraisals Services Terms and Conditions.
3. The product and the manufacture are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ.
4. BRANZ makes no representation as to:
  - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
  - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
  - c) any guarantee or warranty offered by the Certificate Holder.
5. Any reference in this Certificate to any other publication shall be read as a reference to the version of the publication specified in this Certificate.

For BRANZ

P Robertson  
Chief Executive

Date of issue: 11 July 2005